

Mills Limited Unit 2, Zodiac Business Park, High Road, Cowley Uxbridge UB8 2GU

Contact us on: Tel: 020 8833 2626 Fax: 020 8833 2600 Email: sales@millsltd.com Company No. 00282704 VAT No. 227082574

## Martindale PD690SRD Proving Unit

## **Product Images**

Product Code: C70-2029



## **Short Description**

Safe electrical working requires the use of a voltage indicator that has been proven with a suitable

proving device before and after use to ensure the instrument is working correctly in accordance with the Electricity at Work Regulations.

The PD690SRD is fast and easy to use, instantly supplying the full test voltage for both high and low impedance voltage indicators, test lamps and meters. It comes complete with an over moulded low-profile case with magnetic hanger.

Proves the operation of voltage indicators, multimeters and test lamps up to 690V AC and is ideal for higher voltage, three phase commercial and industrial applications. Also has switchable DC output.

## Description

Safe electrical working requires the use of a voltage indicator that has been proven with a suitable proving device before and after use to ensure the instrument is working correctly in accordance with the Electricity at Work Regulations.

The PD690SRD is fast and easy to use, instantly supplying the full test voltage for both high and low impedance voltage indicators, test lamps and meters. It comes complete with an over moulded low-profile case with magnetic hanger.

Proves the operation of voltage indicators, multimeters and test lamps up to 690V AC and is ideal for higher voltage, three phase commercial and industrial applications. Also has switchable DC output.

Specifications

Output voltage 690V, 440V, 230V, 120V or 50V nominal Output frequency DC or 50Hz nominal Temperature (Operating & Storage) -10°C to 40°C Humidity (Operating & Storage) max. 70% R.H. Altitude up to 2000m Pollution Degree 2 Power 6 x 1.5V, AA alkaline batteries (IEC LR6, NEDA 15A) Dimensions 150 x 80 x 35mm Weight 350g approx. with batteries