

**1. Unique identification code of product-type:**  
PYROC

**2. Type, Batch or serial number as required pursuant to Article 11(4):**  
See ETA 13/1070 : See batch number displayed on product.

**3. Intended use or uses of construction product, in accordance with the applicable harmonized technical specification:**  
Fire Stopping and Sealing Products for Penetration Seals, See ETA 13/1070

|                           |  |  |
|---------------------------|--|--|
| <b>Cable Penetrations</b> | Insulated & non insulated, cables, cable trays & cable ladders | The field of application has to comply with the content of ETA 13/1070 |
| <b>Pipe Penetrations</b>  | Insulated & non insulated metal pipes                          | The field of application has to comply with the content of ETA 13/1070 |

**4. Name, registered trade name or registered trade mark and contact address as required pursuant to article 11(5):**  
FSi Limited, Westminster Industrial Estate, Tamworth Road, Measham, DE12 7DS, UK.

**5. Authorized representative:** N/A

**6. System or systems of assessment and verification of performance of the construction product as set out in Annex V:** AVCP - System 1

**7. Harmonized standard:** N/A

**8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:**  
Warrington Certification Limited issued European Technical Approval - ETA 13/1070 on the basis of ETAG 026 part 1 General June 2013 fire protection products & ETAG 026 part 2 August 2011 fire stopping and fire sealing products & issued certificate of conformity 1121-CPR-JA5009

**9. Declared performance:**

| Essential Characteristics         | Performance/Harmonised technical specification  |
|-----------------------------------|---|
| <b>Reaction to Fire</b>           | Class F According to EN13501-1  |
| <b>Resistance to Fire</b>         | Resistance to fire performance & field of application in accordance with EN13051-2<br>See ETA 13/1070 clause 3.2 - Annex C                              |
| <b>Air Permeability</b>           | Tested in accordance with EN 1026, See ETA 13/1070 Clause 3.3   |
| <b>Dangerous Substances</b>       | See ETA 13/1070 Clause 3.5  |
| <b>Airbourne Sound Insulation</b> | Tested in accordance with EN ISO 10140-2:2010 & EN ISO 140-3 & EN ISO 717-1 See<br>ETA 13/1070 Clause 3.9 - Rw (C;Ctr) = 63 (G;-2) dB & Rw (C;Ctr) 38dB |
| <b>Service &amp; Durability</b>   | Z <sup>1</sup> (0/+40°C) intended for use at internal conditions with high humidity (85%) in<br>accordance with EOTA technical documents TR024          |
| <b>Movement Capability</b>        | According to ISO 11600 : ISO 11600 - F - 12.5p.   |
| <b>Other</b>                      | Not applicable/No performance determined  |

**10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 6. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.**

**Signed for and on behalf of the manufacturer by:**



01/06/2015

**C. Atkinson - Managing Director**



01/06/2015

**L. Peach - Technical Manager**